



# EEEEV.MH29973 - ABOVEGROUND FLAMMABLE-LIQUID TANKS

## Aboveground Flammable-liquid Tanks

See General Information for Aboveground Flammable-liquid Tanks

### **MARENGO FABRICATED STEEL LTD**

MH29973

1089 County Rd 26

Po Box 179

Marengo, OH 43334-0179 USA

Aboveground tanks for flammable liquids

Aboveground tanks for flammable liquids on supports

Aboveground tanks for flammable liquids with supports

Secondary containment aboveground tanks for flammable liquids

Last Updated on 2019-07-30

---

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"

# EEEEV.GuideInfo - ABOVEGROUND FLAMMABLE-LIQUID TANKS

## [Containment Products for Flammable and Combustible Liquids] (Fixed and Stationary Storage Tanks) Aboveground Flammable-liquid Tanks

See General Information for Fixed and Stationary Storage Tanks

### USE AND INSTALLATION

This category covers general-purpose, shop-fabricated, steel primary, secondary and diked containment-type tank constructions intended for aboveground storage of noncorrosive, stable, flammable and combustible liquids of maximum 1.0 spg at atmospheric pressure in capacities from approximately 60 gal to 75,000 gal.

These tanks are intended for fixed or stationary installation and use in accordance with ANSI/NFPA 30, "Flammable and Combustible Liquids Code," ANSI/NFPA 30A, "Code for Motor Fuel Dispensing Facilities and Repair Garages," ANSI/NFPA 31, "Installation of Oil-Burning Equipment," ANSI/NFPA 37, "Installation and Use of Stationary Combustion Engines and Gas Turbines," ANSI/NFPA 1, "Fire Code," the "International Fire Code" (published by the International Code Council), and/or other requirements of the Authority Having Jurisdiction (AHJ).

This category covers only the basic tank constructions and optional tank accessories specifically identified in the individual certifications that are investigated to additional requirements under the base tank standards.

This category does not cover field-erected tanks or portable/mobile tanks intended for shipping and transport, which are covered under separate requirements or regulations from the American Petroleum Institute, U.S. Department of Transportation, etc., or United Nations publications; or special-purpose tanks, such as utility or used oil.

These products have not been investigated for resistance to or use after hurricanes, tornadoes, earthquakes, floods or other natural disasters; or vehicle and similar impacts; and fire.

### TANK TYPES

The following types of steel tank basic-containment constructions, designs and optional supports are indicated in the individual certifications:

**Aboveground tank for flammable liquids (#)** — Single-wall steel primary-containment tank.

**Secondary-containment aboveground tank for flammable liquids (#)** — Steel primary-containment tank within a steel secondary-containment shell forming an interstitial space capable of being pressurized and monitored for leakage.

**(\*) Diked aboveground tank for flammable liquids (#)** — Steel primary-containment tank within a steel containment dike vessel capable of being monitored for leakage, but not capable of being pressurized.

**(#) "on supports"** — Optionally provided with supports to elevate and stabilize the tank above grade that are investigated for structural integrity.

(\*) Diked tank designs are either:

**"Open-top"** — Dikes provided without covers that resist rain or debris entering the dike.

**"Closed-top"** — Dikes provided with covers that resist rain or debris entering the dike.

### TANK ACCESSORIES

The following optional accessories noted in the individual certifications and investigated to additional requirements in ANSI/UL 142, "Steel Aboveground Tanks for Flammable and Combustible Liquids," may also be attached to the base tank:

**Access devices** — Ladders, stairs or runways provided for access, working or walking surfaces on the tank.

**Lifting devices** — Structural lugs, hooks or others means to facilitate lifting of the tank during fabrication, transport or installation.

**Heating devices** — Heating coils or hot wells provided within the tank for heating liquids in the tank.

## FEATURES COVERED

The basic features of tanks covered under this category include all containment spaces and their respective openings (manways, emergency vents, normal vents, fill/withdraw, gauging, monitoring and other functional openings) with connections (threaded- or flanged-type fittings), and the tank accessories identified above.

All primary-tank compartment(s) are provided with normal and emergency vent openings. All secondary-tank interstitial space(s) are provided with emergency vent openings. It is anticipated the continued venting will be provided when installed in accordance with the applicable code.

In addition to vent openings, all primary-tank compartment(s) are provided with openings to accommodate filling, withdrawing, and inventory control; and all secondary-tank interstitial spaces are provided with openings for leak-detection monitoring.

Accessories (when provided) are attached to the tank or, where attachment at the factory is not possible (due to size/weight limits and/or potential damage), may be shipped with assembly instructions separately from or with the base tank.

All tank-containment compartments have been factory leak-tested by the manufacturer before shipping.

## ACCESSORIES/FEATURES NOT INVESTIGATED

This category covers only the accessories and features specifically identified in the individual certifications. Any other accessories or components that are shipped with the tanks, attached to the tanks, or added to the tanks are not included in the scope of the tank certification. It is intended that the AHJ approve the use and/or installation of any such accessories independent of the tank certification.

In cases where either the tank is not marked for a specific fuel blend, or the liquid(s) to be stored in the tank is not known by the manufacturer, manway gasket compatibility is determined by the tank buyer.

## RELATED PRODUCTS

See Fire-resistant Aboveground Tanks for Flammable and Combustible Liquids (EEZI) for tanks investigated to UL 2080, "Fire Resistant Tanks for Flammable and Combustible Liquids."

See Protected Aboveground Tanks for Flammable and Combustible Liquids (EELU) for tanks investigated to ANSI/UL 2085, "Protected Aboveground Tanks for Flammable and Combustible Liquids."

See Below-grade Vaults for Flammable-liquid Storage Tanks (EHOJ) for below-grade vaults investigated to UL 2245, "Below-Grade Vaults for Flammable Liquid Storage Tanks."

See Special-purpose Tanks (EFVT) for tanks constructed of steel, including generator base, work-top, lube oil, waste oil, day/utility, and other special-purpose types investigated to UL 142A, "Outline of Investigation for Special Purpose Aboveground Tanks for Specific Flammable or Combustible Liquids."

## ADDITIONAL INFORMATION

For additional information, see Fixed and Stationary Storage Tanks (EDQX), Containment Products for Flammable and Combustible Liquids (ECPR) and Flammable and Combustible Liquids and Gases Equipment (AAPQ).

## REQUIREMENTS

The basic standard used to investigate the basic tank-containment type and optional accessories in this category is ANSI/UL 142, "Steel Aboveground Tanks for Flammable and Combustible Liquids."

## UL MARK

The Certification Mark of UL on the product is the only method provided by UL to identify products manufactured under its Certification and Follow-Up Service. The Certification Mark for these products includes the UL symbol, the words "CERTIFIED" and "SAFETY," the geographic identifier(s), and a file number.

## Alternate UL Mark

The Listing Mark of UL on the product is the only method provided by UL to identify products manufactured under its Listing and Follow-Up Service. The Listing Mark for these products includes the UL symbol (as illustrated in the Introduction of this Directory) together with the word "LISTED," a control number, and the name of the appropriate tank construction as indicated in the individual Listings.

\* \* \* \* \*

UL, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. UL shall not incur any obligation or liability for any loss, expense or damages, including incidental or consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Guide Information.

Last Updated on 2018-04-13

---

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"





# TSQT.E236061 - COMMERCIAL COOKING, RETHERMALIZATION AND POWERED HOT-FOOD- HOLDING AND -TRANSPORT EQUIPMENT

## Commercial Cooking, Rethermalization and Powered Hot-food- holding and -Transport Equipment

See General Information for Commercial Cooking, Rethermalization and Powered Hot-food-holding and -Transport Equipment

**DARLING INTERNATIONAL INC**

E236061

251 O Connor Ridge Blvd Ste 300  
Irving, TX 75038-6510 USA

**Grease storage tanks**, Model(s) 1500C, 1500D, 1500GRN, 1500H, 2036C, 2036H, BOSS Spacesaver, F4F

**Used cooking oil caddy**, Model(s) 401, 401A, 402, 404, 405

Some models may also have Safety Certification.

Last Updated on 2018-04-25

---

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"



# TSQT.GuidelInfo - COMMERCIAL COOKING, RETHERMALIZATION AND POWERED HOT-FOOD-HOLDING AND -TRANSPORT EQUIPMENT

## [Sanitation, Food Service Equipment] Commercial Cooking, Rethermalization and Powered Hot-food-holding and -Transport Equipment

See General Information for Sanitation, Food Service Equipment

### USE

This category covers cooking and hot-food-holding equipment, including brewers, steam tables, griddles, broilers, ovens, fryers, food warmers, and similar equipment intended for commercial use.

### PRODUCT MARKINGS

Equipment may be marked with use limitations or may provide guidance on intended application.

Rethermalization equipment is provided with a marking that specifies the maximum capacity of the unit.

Equipment provided with a security package for installation in areas where security may be a concern is marked "Intended for use only in environments where security is a concern, such as correctional facilities, mental health facilities, or some schools."

### PRODUCT IDENTITY

One of the following product identities appears on the product:

Cooking Equipment

Hot-food-storage Equipment

Other product identities may be used as shown in the individual certifications.

### RELATED PRODUCTS

Electric equipment and warming and serving equipment intended for commercial use and investigated to UL Safety Standards is covered under Commercial Cooking Appliances (KNGT) and Custom-built Food-service Equipment (KNNS).

Gas-fired food service equipment is covered under Gas-fired Food Service Equipment (LGQX).

See Lead Content Verification of Products in Contact with Potable Water (QNVB).

### ADDITIONAL INFORMATION

For additional information, see Food Safety and Quality, Products and Equipment (AAFS).

### REQUIREMENTS

The basic standard used to investigate products in this category is NSF/ANSI 4, "Commercial Cooking, Rethermalization and Hot Food Holding and Transport Equipment."

### UL MARK

The Certification Mark of UL on the product is the only method provided by UL to identify products manufactured under its Certification and Follow-Up Service. The Certification Mark for these products includes the UL symbol, the words "CERTIFIED" and "SANITATION," and a file number.

## Additional Certification Markings

Products covered under this category are additionally marked with the following information:

### NSF/ANSI 4

For those products which are also certified by UL under another category, the statement "NSF/ANSI 4" is included on the product.

## Alternate UL Mark

The Classification Mark of UL on the product is the only method provided by UL to identify products manufactured under its Classification and Follow-Up Service. The Classification Mark for these products includes the EPH Mark (as illustrated in the Introduction of this Directory) and the following additional information:

### [PRODUCT IDENTITY\*]

#### NSF/ANSI 4

#### Control No.

\* **COOKING EQUIPMENT** or **HOT FOOD STORAGE EQUIPMENT**, or other appropriate product name as shown in the individual Classifications

For those products which are also Listed or Classified by UL under another category, the marking includes the appropriate Listing or Classification Mark, the EPH Mark, and the text "NSF/ANSI 4" below the EPH Mark.

\* \* \* \* \*

UL, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. UL shall not incur any obligation or liability for any loss, expense or damages, including incidental or consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Guide Information.

Last Updated on 2016-07-13

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"